




*Achieving Excellence - the Facilities
Management and Sustainability Workshop*

June 17, 2011

Demand Response

Donald Lincoln, PhD, PE

nStone Corporation



Demand Response


- **The Purpose of Demand Response (DR)**
- **DR Compensation**
- **UNM Control System Design**
- **Sandia National Laboratories DR Pilot**

The Purpose of Demand Response



The Purpose of Demand Response

California ISO, Sept 05 – Sept 06



The Purpose of Demand Response

Voluntary action by customers to change their consumption of electric power in response to:

- **Direction**
- **Incentives**
- **Price Signals**

from grid operators at times of **high wholesale market prices** or when electric suppliers **reserve margins are low**.

Typical Time Period: 12:00 noon to 7:00 pm

Typical Frequency: 8 to 15 times per year

The Purpose of Demand Response

Benefits of Demand Response

- Reduction in wholesale power prices
- More efficient operation of power markets
- Enhances reliability of power system
- Environmental benefits due to reduced generation
- Cost savings from avoided/deferred new generation and T&D

FERC DR Savings Estimates by 2019:

Business as Usual (BAU)	4%	38 GW
Expanded BAU	9%	82 GW
Achievable Participation	14%	138 GW
Full Participation	20%	188 GW

DR Compensation


Economic Drivers

- Fuel Cost Savings (50-70 \$/MWh)
- Wholesale Price of Electricity on Peak (1000 – 5000 \$/MWh)
- Avoided/Delayed Capital Cost for New Peaking Generation (~1500+ \$/MWh)



DR Compensation

FERC Order 745, 3/15/2011 –
wholesale market price at time
supplied



DR Compensation

Independent System Operator (ISO)/ Regional Transmission Org. (RTO)	Price Cap/ \$/MWH
• California ISO (CAISO)	• \$1000
• Electric Reliability Council of Texas (ERCOT)	• \$5000
• Southwest Power Pool (SPP)	• \$1000
• Midwest ISO (MISO)	• \$1000
• PJM Interconnection (PJM)	• \$2700
• New York ISO (NYISO)	• \$1000
• ISO New England (ISO NE)	• \$1000


UNM DR Control System Design

- **The University of New Mexico (UNM) Campus**
- **System Design Parameters**
- **DR Control System**
- **Results**



The University of New Mexico (UNM) Campus

The DR Facilities



- 69 Facilities
- 75% total campus facility area
- Over 90% facility energy use
- Range from 240,000 sq ft to 3,600 sq ft
- Average 71,000 sq ft
- Ave construction date 1964, standard deviation 20 years
- Assume HVAC use VAV with VFD control
- Assume lighting controls through EMCS

System Design Parameters

UNM Parameters


- Raise temperatures in facilities less as occupancy increases

Occupancy		T Set Point
Low	< 20%	80 °F
Med.	20% to 60%	78 °F
High	60% to 90%	76 °F
V. High	> 90%	74 °F

- Participation voluntary (lighting or HVAC)
- Control system will achieve a specific reduction target based on energy price versus percent reduction curve
- For reduction < 100%, facilities chosen randomly

DR Control System

UNM EMCS – Energy Management and Control System





DR Control System

Price Control Strategy

- Power reduction = $f(\text{energy price})$
- Could also be used for conservation on TOU rates

Example




DR Control System

Input:

- Price this hour
- Facility Table
- Facility Population Table

System Flow Chart



Facility DR Table (FDRT)

DR Control System Input - Facility Table (FacT)

#	Bldg #	Building	SF	Lights, kW (1.1 w/sf)	Light DR Particip	Temp DR Particip
1	157	Alvarado	40,896	45	0	1
2	76	Anderson School of M	46,406	51	1	1
3	12	Anthropology Annex	9,614	11	1	0

Light kW Reduction Participants	76F kW Reduction Participants	78F kW Reduction Participants	80F kW Reduction Participants
9	13	26	39
10	15	29	44
2	3	6	9

69	331	Crystal Growth Fac	5,110
----	-----	--------------------	-------

DR Control Strategy Input - Facility Population Table (Fpop)

Table for Each Day, Monday - Friday

#	Bldg #	Building
1	157	Alvarado
2	76	Anderson School of M
3	12	Anthropology Annex

12:00	1:00	2:00	3:00	4:00	5:00	6:00
L	L	L	L	M	M	H
H	M	H	H	L	L	L
L	L	L	H	S	H	L

69	330	Crystal Growth Fac
----	-----	--------------------

DR Control System

Output - Facility Demand Response Table (FDRT)


#	Bldg #	Building	Lighting DR						
			12:00	1:00	2:00	3:00	4:00	5:00	6:00
1	157	Alvarado	0	0	0	0	0	0	0
2	76	Anderson School of M	1	1	1	1	1	1	1
3	12	Anthropology Annex	1	1	1	1	1	1	1

Thermostat Set Point DR						
12:00	1:00	2:00	3:00	4:00	5:00	6:00
74	74	80	80	78	78	74
74	74	74	74	80	80	74
74	74	74	74	74	74	74

69	330	Crystal Growth Fac	----->
----	-----	--------------------	--------

Results


Price 30 cents/kWh, 50% Reduction at 1:00 pm



- Campus Peak 25.0 MW
- DR Reduction 2.6 MW
1.1 MW no light
- 80 deg F - 28
- 78 deg F - 0
- 76 deg F - 0
- Lighting Only 31
- No HVAC Participation 7
- No Lighting Participation 22

Results

Price 86 cents/kWh, 100% Reduction at 4:00 pm



- Campus Peak 25.0 MW
- DR Reduction - 4.2 MW
3.5 MW no light
- 80 deg F - 32
- 78 deg F - 29
- 76 deg F - 1
- Lighting Only 0
- No HVAC Participation 7
- No Lighting Participation 22

Summary

The DR Control System

- Manages DR event for 69 UNM facilities.
- Designed to reduce power based on energy price.
- Could potentially reduce UNM power by 3000 to 4,500 kW.

Additional Exploratory Work

- Improve the DR reduction estimates for each facility based on actual reduction each hour.




Demand Response Pilot at SNL - Summer 2011

SNL Pilot

DR Pilot Plan SNL Summer 2011

- 41 facilities (1.88M square feet) to include in the DR event,
- Participation of the Air Force,
- The automatic control strategy,
- The specific targets for electric use reduction (HVAC, Cold Water Storage, Computing),
- No control system modifications or upgrades,
- The estimated cost to perform the DR event pilot low,
- The strategy to communicate the DR event to customers

DR Pilot Test – Building 969



SNL Pilot

Sandia National Laboratories - Assumptions:

- SNL Peak Electric Use – 45.3 MW
- 12 DR Events per year at 6 hours duration each
- 5% to 10% from HVAC DR (2.27 MW to 4.53 MW)
- Computing & Network Services (C&NS) – 6 MW with 33% reduction
- DR valued at wholesale market price cap per MWH (\$1000, \$2500, \$5000)

Compensation Range per Year

<u>\$/MWH Price Cap</u>	<u>\$1000</u>	<u>\$2500</u>	<u>\$5000</u>
<u>5% from HVAC DR, 33% C&NS</u>	\$300K	\$770K	\$1,500K
<u>10% HVAC DR, 33% C&NS</u>	\$500K	\$1,200K	\$2,400K

Discussion

Backup Slides

Implementation


Dynamic Versus Static Pricing

Example Time-of-Use Rates

	Off Peak cents/kWh	Near Peak cents/kWh	On Peak cents/kWh
Madison Gas & Electric	3		29
Salt River Project	6.7		21.3
Arizona Public Service	5		24
San Diego Gas & Electric	7		38
Progress Energy	5.4		17.1
Ontario Hydro	5	8	10
Reliant Power	12.1	15.5	17.5
Baltimore Gas and Electric	9.9	11.5	14.9


Implementation

Critical Peak Pricing - California




SNL FY 2010

SNL Power Use 8/2009 to 8/2010
Feeders 5, 6, and 7



SNL FY 2010

SNL Power Use 8/09 to 8/10
Feeders 5, 6, and 7



Implementation Issues

	Commercial	Residential
Manual	Facility operator takes specific action	Customer raises thermostat and turns off appliances
Auto	Automated control system responds	AMI with smart thermostat and smart appliances