

Alerting Techniques

NFPA 70 - 2009 Article 130.7(E)(4)
“Look-Alike Equipment”

Daryld Ray Crow

DRC Consulting, Ltd.

Phone : 704-564-4230

Email: draycrow@aol.com

WORK ZONES/BARRICADES

Use Work Zones/Barricades around
“look-alike” equipment.

“Alerting Techniques”

See 130.7 (E)(4)





Is This Look-Alike Equipment?



LOOK-ALIKE EQUIPMENT

“Look-alike” equipment can be a killer. **This is a real hazard.** This type of injury or death continues to happen in industry.


IT COULD HAPPEN TO YOU!!!

CASE HISTORIES

Problem found In These Two Locations

C5 Term	A4 Term	R1 Xfmr	480 Volt Switchgear Secondary Breakers	R2 Xfmr	A4 Term	C5 Term
C5 Switch	A4 Switch				A4 Switch	C5 Switch


Deenergized for Work
No Work Zone in Place





Employee was injured when she
went to work here by mistake











G&W

Transcendental Meditation

Transcendental Meditation


Transcendental Meditation

Transcendental Meditation












What if red tape had been used to prevent entry into compartments with exposed live parts?




SWGR 21



SWGR 21



Barricaded Work Zone





Barricaded Work Zone



Identify equipment still energized.

Under HV Permit

Danger - High Voltage Keep Out

Danger - High Voltage Keep Out

Danger - High Voltage Keep Out

Danger - High Voltage Keep Out

Danger - High Voltage Keep Out

Danger - High Voltage Keep Out

Danger - High Voltage Keep Out

Identify equipment covered by the work zone.



SS13

SS132

DANGER
6,600 VOLT

UNDER H.V. PERMIT
ALCOA RW

SS 132

DANGER
6,600 VOLTS

SS 13

DANGER
ALCOA RW

WORK ZONES

Sometimes the right tool is a roll of red tape



Case History

Improper Labeling and Look Alike Equipment
A Dangerous Combination

Qualified People Make Mistakes


- Traps Exist In The Work Place!
- Do You “Bet Your Life” That The Labeling On The Equipment Is Correct?
- Do You Test for Voltage Before You Touch Exposed Electrical Conductors or Circuit Parts That Might Be Energized?

Testing for the Absence of Voltage

- Are You Sure You Made a Valid Test?
- What Type of Voltmeter Should You Use?




Know your Instrument
What will it do?
What will it not do?



Use of non-contact voltage testers;
Cadick & Liggett; IEEE IAS 2007 Electrical
Safety Workshop

Phase-to-Phase Test Limitations



Meter Does Not Indicate Voltage

Testing for the Absence of Voltage

- Are You Sure You Made a Valid Test?
- What Type of Voltmeter Should You Use?
- How Do You Test for Voltage Where Contact Is Not Possible?



The Task

- Two pieces of identical equipment existed in the field. A problem existed with one of them.
- Equipment # 2 would not start. A work order was placed to have an electrician find and correct the problem.

Note: Before the work order was placed, the disconnect switch for equipment # 2 had been opened and a problem was found inside the disconnect switch.

Warning

- Traps exist in the workplace.


The labeling on the breakers feeding the two pieces of equipment were reversed.



EQ #2

EQ # 1

EQ # 1



EQ #1

EQ # 2

EQ # 2

Fed from Bkr
Labeled EQ #2



Fed from Bkr
Labeled EQ #1





EQ # 1


EQ # 2

Note: The electrician had opened, locked, and tagged the breaker labeled "EQ # 2" before testing for the absence of voltage on the line side of the disconnect switch labeled "EQ # 2"

A Trap

- Equipment # 1 stopped running when the breaker labeled equipment # 2 was opened.
- The electrician did not think it was abnormal for equipment # 1 to not be running because this equipment automatically starts and stops based on the need for cooling.

During testing the arc suppressor prevented the voltmeter leads from making positive contact with exposed energized conductors on the line side of the disconnect switch.



The Incident

- An arc occurred when work took place inside the disconnect switch feeding equipment # 2
 - A part that was removed made contact with an energized 480 volt conductor and ground
- No injury occurred because of the Electrician's PPE
 - HRC 1 clothing
 - Class 0 rubber insulating gloves with leather protectors
 - Used insulated tools



HRC 1 Dress
Note the Arc-Rated
Face Shield

Root Causes of Incident

- The labeling was not correct.
- No contact was made with an exposed part during testing for the absence of voltage with a voltmeter that required contact with an exposed part.
- The arc suppressor on the disconnect switch prevented the voltmeter leads from making contact with the exposed energized conductors.
- The electrician thought that he had checked for the absence of voltage.

Lessons Learned

- The use of a non-contact voltage tester may have prevented the incident.
- When you use a voltmeter that requires contact with exposed parts **make sure you do.**
- Don't "bet your life" that the labels on equipment are correct.



Bad things happen
when you do not pay
attention to details

An Independent Question

- What safeguards do you have in place to help prevent a person from using a voltmeter rated for 1000 volts to check for voltage on a high voltage system?

Can you tell that
this is 4160 Volt
Equipment?



Warning
4160 Volts



PANEL
HFG

DANGER
HIGH VOLTAGE

Warning
4160 Volts

DANGER
HIGH VOLTAGE



What do you have in place to prevent this from happening?

- Results of using a voltmeter rated for 1000 volts on 4160 volt equipment



4160 Voltage fault due to improper meter being used

- PPE of the tech doing the measurement
- What if no PPE had been used?





Use an **adequately rated voltage detector** when testing for voltage

Qualified People Make Mistakes

- Questions?

For More Information, Contact:

Daryld Ray Crow

DRC Consulting, Ltd.

Phone : 704-564-4230

Email: draycrow@aol.com

A background image of a lightning bolt striking a tree, with the lightning appearing as bright purple and white streaks against a dark, stormy sky. The tree is silhouetted against the light from the lightning.

Lightning can strike at any time!

Have effective job briefings
Test before you touch
Create an electrically safe work condition

Never take short cuts!

Beliefs Drive Behaviors

91% of all electrical incidents are caused by
unsafe work practices