

# Workshop #2

## 10 CFR 851

October 8 – 9 2009

Pasco WA

# Workshop #2

## 10 CFR 851

- Deliverable
- NFPA 70E 2009 Evaluation to determine if it's "as safe" as 2004.
- EFCOG Position Paper with any exceptions.
- Due date Dec 15 2009

# Workshop #2

## 10 CFR 851

- Exceptions
- Art 130.1 (B) Energized Electrical Work Permit.
- (1) Where required.
- When working on vs when working on or near.
  
- Art 320.7 Protection.
- (E) Section Isolating Switch.
- Change to 250VDC from 120VDC