



Washington Group International

Integrated Engineering, Construction, and Management Solutions

Fire Analysis Preparation Implementation Approaches – Sample Problems

Energy Facility Contractors Group (EFCOG), Safety Analysis
Working Group (SAWG) Fall 2007 Workshop,
November 6 & 7, 2007 Albuquerque, NM

Allan Coutts, FSFPE & Andrew Vincent
803.502.9811, allan.coutts@wsms.com

Overview of Presentation

- ◆ **Source Term Calculation Refresher**
- ◆ **Problem Description**
- ◆ **Strategy 1 - Very bounding**
- ◆ **Strategy 2 - Recognize limited combustibles**
- ◆ **Strategy 3 – Inclusive analysis**
- ◆ **Comparison of Results**

Source Term Calculation – Refresher

ST **Source Term**

MAR **Material at Risk**

DR **Damage Ratio**

ARF **Airborne Release Fraction**

RF **Respirable Fraction**

LPF **Leap Path**

$$\mathbf{ST = MAR \cdot DR \cdot ARF \cdot RF \cdot LPF}$$

Sample Problem – Strategy 1

- ◆ **Assumption: Combustibles will cause complete evaporation of tank contents**
 - MAR: 2.5 kg
 - DR: 1.0
- ◆ **Assumption: Vigorously burning solvent over aqueous phase burning to dryness**
 - ARF: 1E-01
 - RF: 1.0
 - LPF: 1.0

$$ST = (2.5 \text{ kg}) (1.0) (1E-01) (1.0) (1.0) = 0.25 \text{ kg}$$

Sample Problem – Strategy 1 (con't)

◆ Unmitigated MOI Dose

- Source Term: 0.25 kg
- Dose Conversion: 900 rem/kg

$$\text{Dose} = (0.25 \text{ kg}) (900 \text{ rem/kg}) = 220 \text{ rem}$$

- This challenges 25 rem guideline

◆ Mitigated Dose (credit ventilation)

- LPF = 0.0003 (99.97% efficient)
- ST = (2.5 kg) (1.0) (1E-01) (1.0) (0.0003) = 7.5E-04 kg

$$\text{Dose} = (7.5\text{E-}04 \text{ kg}) (900 \text{ rem/kg}) = 0.67 \text{ rem}$$

Sample Problem – Strategy 1 (con't)

- ◆ **Credited SSCs**
 - Cell Structure – SC
 - Cell Ventilation – SC
- ◆ **Credited SACs**
 - Cell inventory limit – 2.5 kg
- ◆ **Additional Considerations**
 - Must demonstrate fire does not compromise ventilation system
 - Must demonstrate fire does not compromise structure

Sample Problem – Strategy 2

- ◆ **Assumption: Very limited amount of combustibles**
 - Combustibles: 200 # mass (3870 MJ energy)
 - MAR: 2.5 kg
- ◆ **Assumption: 10% fire energy to tank**
 - $\Delta H_{f-g} = 2.26 \text{ MJ/kg}$
 - Liquid evaporated = 54 gallons
 - DR = 54 gallons/90 gallons = 0.6
- ◆ **Assumption: Boiling aqueous solution in flowing air**
 - ARF: 2E-03
 - RF: 1.0
 - LPF: 1.0

$$ST = (2.5 \text{ kg}) (0.6) (2E-03) (1.0) (1.0) = 0.003 \text{ kg}$$

Sample Problem – Strategy 2 (con't)

◆ Unmitigated MOI Dose

- Source Term: 0.003 kg
- Dose Conversion: 900 rem/kg

$$\text{Dose} = (0.003 \text{ kg}) (900 \text{ rem/kg}) = 2.7 \text{ rem}$$

- ◆ This does not challenge 25 rem

Sample Problem – Strategy 2 (con't)

◆ Credited SSCs

- None

◆ Credited SACs

- Cell inventory limit: 2.5 kg
- Very restricted combustible limit (200 #)

◆ Additional Considerations

- Concept does not assure protection of worker
- Combustible limit importance is uncertain

Sample Problem – Strategy 3

- ◆ **Assumption: Combustible loading is limited**
 - Combustibles: 10 psf (640 # wood equiv; 5,400 MJ)
 - MAR: 2.5 kg
- ◆ **Assumptions: 10% fire energy to tank**
 - ΔH_{f-g} : 2.26 MJ/kg
 - Liquid evaporated: 63 gallons
 - DR: 63 gallons/90 gallons = 0.7
 - ARF: 2E-03
 - RF: 1.0
 - LPF: 1.0

$$ST = (2.5 \text{ kg}) (0.7) (2E-03) (1.0) (1.0) = 0.0035 \text{ kg}$$

Sample Problem – Strategy 3 (con't)

◆ Unmitigated MOI Dose

- Source Term: 0.0035 kg
- Dose Conversion: 900 rem/kg

$$\text{Dose} = (0.0035 \text{ kg}) (900 \text{ rem/kg}) = 3.1 \text{ rem}$$

◆ This does not challenge 25 rem

Sample Problem – Strategy 3 (con't)

- ◆ **Assumption: Cell structure is reinforced concrete rated for >2 hours**
 - Fire loading (10 psf) would not be expected to cause cell structure to fail (qualitative assessment)

Sample Problem – Strategy 3 (con't)

◆ Filter plugging

- Soot fraction: 0.2 kg/kg consumed
- Mass consumed: 600 #, 272 kg

$$\text{Soot demand} = (0.2) (272 \text{ kg}) = 54 \text{ kg}$$

- Typical load to cause plugging: 0.5 kg/filter
- Number of filters: 9

$$\text{Soot capacity} = (9 \text{ kg}) (0.5 \text{ kg/filter}) = 4.5 \text{ kg}$$

- Capacity < Demand
- Filter pluggage expected

Sample Problem – Strategy 3 (con't)

- ◆ **Credited SSCs**
 - Cell structure maintains stability during fire
- ◆ **Credited SACs**
 - Cell inventory limit – 2.5 kg
 - Combustible loading limit (10 psf)
- ◆ **Additional Considerations**
 - Concept does not assure protection of worker
 - Ventilation system may not need to be SC

Sample Problem – Other Considerations

- ◆ **Assumption: Very limited amount of combustibles**
 - Combustibles: 10 psf (640 # wood equiv; 5,400 MJ)
 - MAR: 1.25 kg (45 gallons)
- ◆ **Assumptions: 10% fire energy to tank**
 - $\Delta H_{f-g} = 2.26 \text{ MJ/kg}$
 - Theoretical liquid evaporated = 54 gallons
 - DR = 1.0 (54 gallons/45 gallons)
- ◆ **Assumption: Fire burns to dryness**
 - ARF: 1E-01
 - RF: 1.0
 - LPF: 1.0

$$ST = (1.25 \text{ kg}) (1.0) (1E-01) (1.0) (1.0) = 0.12 \text{ kg}$$

Sample Problem – Other Considerations (con't)

◆ Unmitigated MOI Dose

- Source Term: 0.12 kg
- Dose Conversion: 900 rem/kg

$$\text{Dose} = (0.12 \text{ kg}) (900 \text{ rem/kg}) = 110 \text{ rem}$$

◆ This challenges 25 rem

Sample Problem – Filter Capacity

◆ Filter plugging

- Soot fraction: 0.2 kg/kg consumed
- Mass consumed: 50 #, 22.7 kg

$$\text{Soot demand} = (0.2) (22.7 \text{ kg}) = 4.5 \text{ kg}$$

- Typical load to cause plugging: 0.5 kg/filter
- Number of filters: 9

$$\text{Soot capacity} = (9 \text{ kg}) (0.5 \text{ kg/filter}) = 4.5 \text{ kg}$$

- Capacity ~ Demand
- Rely on transfer to alternate train to limit plugging potential

Sample Problem – Strategy 3 (con't)

◆ Credited SSCs

- Ventilation system – SC
- Building structure - SC

◆ Credited SACs

- Cell inventory limit – 2.5 kg
- Combustible loading limits
 - 50 pounds (Prevents filter pluggage)
 - 10 psf (Protects structure)

◆ Additional Considerations

- Ventilation system will protect workers
- Treat fire with ventilation pluggage as beyond design basis accident

Comparison of Sample Results

	Strategy 1 Full evaporation	Strategy 2 Limited combustibles	Strategy 3 Inclusive
Public unmitigated dose	220 rem	2.7 rem	3.1 & 110 rem
Ventilation system	Not evaluated	SS – uncertain SC - no	SS – active SC - passive
Building structure	Not evaluated	SC	SC
Radiological inventory	2.5 kg (SAC)	2.5 kg (SAC)	2.5 kg (SAC)
Combustible loading	Unlimited	200 # plastic (SAC) 10 psf (AC)	50 # wood equiv. (SAC) 10 psf (AC)
Comment	Analysis incomplete	Won't work for low inventory	Filter pluggage BDBA